

Declaration of Conformity

Issued by Manufacturer
Hoffman Enclosures, Inc.

2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.

declare at our sole responsibility, that these devices are designed and constructed according to
the fundamental safety and health requirements.

Enclosure Models: ASE#X#X#SSNK (where # denotes size) (Bulletin A90S4)

Equipment Description: TYPE 4X INDUSTRIAL CONTROL JUNCTION BOXES

Enclosure Rating : NEMA / UL / cUL Type 3, 3R, 4, 4X, 12

Enclosure Certification: UL508A Listed File E27525

Applicable Standards: UL508A Industrial Control Panel Enclosure
UL 50 Enclosures for Electrical Equipment, Non-
Environmental Considerations
UL 50E Enclosures for Electrical Equipment, Environmental
Considerations
cUL to CSA C22.2 No. 94.1 and 94.2
NEMA250 Enclosures for Electrical Equipment (1000 Volts
Maximum)

File E27525

Vol. 1

Sec. 6

Page 1

and Report

Issued: 2015-10-17

Revised: 2016-04-05

PRODUCT COVERED:

USL, CNL - Pull box models ASE##X###XXNK, where # is any number, and X is any letter.

PRODUCT COVERED:

Boxes, junction and pull boxes, Types 3, 3R, 4, 4X and 12 sheet metal enclosures.

Authorized by:



Tom Hurney

Technology Mgr., Product Compliance and Approvals

2/18/2022

Date

Subject to Change Without Notice

DOC: CERT-00238 E

CERTIFICATE OF COMPLIANCE

Certificate Number 20190805-E27525
Report Reference E27525-20151017
Issue Date 2019-AUGUST-05

Issued to: Hoffman Enclosures Inc
2100 Hoffman Way
Anoka MN 55303-1738

This certificate confirms that
representative samples of

BOXES, JUNCTION AND PULL

Pull box models ASE##X###XXNK, where # is any number,
and X is any letter.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 50 and CSA C22.2 NO. 94.1.15 - ENCLOSURES FOR
ELECTRICAL EQUIPMENT, NON-ENVIRONMENTAL
CONSIDERATIONS.

UL 50E and CSA C22.2 NO. 94.2-15 - ENCLOSURES FOR
ELECTRICAL EQUIPMENT, ENVIRONMENTAL
CONSIDERATIONS.

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.

B. Mahle

Bruce Mahle, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/about/location/>.

