



Catalog Number: 8824-GSC1
Item Description: N1 SCREW CVR GUTTER
UPC Code: 784572109254


Brand Name: Milbank
Type: Lay In Wireway
Application: Wireway
Standard: UL Listed, Type 1
Cover Type: Screw Cover
Enclosure: Indoor Enclosure
Nominal Cross Section: 8x8
Straight Section Length: 24
Material: Steel with Powder Coat Finish
Finish: ANSI 61 Gray
Knockouts: True




Additional Specifications: UL Listed:UL Listed
NEMA Rating:Type 1

Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.



CATALOG#	LABEL#
8824-GSC1(-)	1002943
RC-8824-GSC1(-)	1125051
SPS-882(-)	1132575



NO.	QTY.	PART NO.	DESCRIPTION
1	1	(SEE CHART)	BACK
2	1	(SEE CHART)	PLATE/COVER
3	1	(SEE CHART)	UL LABEL, WIREWAY
4	1	1002913	LABEL, RATING
5	4	1001290	SCREW, 10-32 X 5/16
6	2	1002880	BAG ASSY (NOT SHOWN)



SUFFIX	BACK #	COVER #
-SU	1001343	1003397
-SUC	1129038	1129031
-SO	1129039	1011824
-SUNK	1001327	1003397
-NK	1010694	1011824
-SUNKC	1129040	1129031



SUFFIX	FINISH
NONE	PAINTED
-NP	NOT PAINTED

NOTE:
1. PLACE BAG ASS'Y INSIDE ENCLOSURE. (NOT SHOWN)

D	2/17/14	UPDATED TO M2K WAS 255-11 eECR2718	AJS	C	8-29-07	ADDED BACK & COVER CHART ECO. 15946	DL	Scale:	NTS	Checked By:	
B1	8-9-06	mECO #14958, ADDED NOTE #2.	CMW	C1	5/7/08	ADDED CHART & REMOVED NOTE#2(ECO.17139)	JLT	Drawn By:	DY	Approved By:	

Material:	14 GA. - SEE CHART		
Finish:	SEE CHART		
Tolerances:	Unless Specified Otherwise	Third Angle	
X.X	$\pm .1$		
X.XX	$\pm .03$		
X.XXX	$\pm .015$		
X"	$\pm 2^\circ$		
		Projection	
Catalog No.:	(SEE CHART)		
Customer:	MILBANK STANDARD		
Drawing No.:	1002637-11		
Date:	08/19/02	Sheet	1 of 1

MILBANK
MANUFACTURING CO.

General Offices:
Kansas City, MO

SCREW COVER WIREWAY
8 x 8 x 24, TYPE 1
NEMA ENCLOSURE

(SEE CHART)

MILBANK STANDARD

1002637-11